

Inspection Report - Fire Bucket Inspection Checklist (Inspection UID - I/MHC/GRR/FBI/26/00005)

Inspection Information

Inspection Type	Fire Bucket Inspection Checklist	Inspection Status	Approved
Site Name	Alanreed	Created on	04-Feb-2026 12:16:31 PM
Asset	FB	Non Oqsha Assets	
Next Inspection Date	04-Mar-2026 12:16:31 PM	Next Inspection Overdue Days	28

Sections

Inspection checks

Company name: My Home Constructions Private Limited	Contractor name: Nakka Phanindra Kumar EHS
--	---

Attachments
Image

Equipment Status

Equipment Status at Site: In Site	Equipment Usage Status: In Usage
--	---

Check Points

Is the bucket free from rust, dents, or cracks?: Yes	Is the bucket painted red with "FIRE" clearly marked in white lettering?: Yes	Is the bucket free from any contamination (e.g., oil, dirt, or debris)?: Yes	Is the handle securely attached and free from damage?: Yes
Does the bucket have a round bottom (for hanging, as per standards)?: Yes	Is the bucket filled with clean, dry sand or water, depending on its designated use?: Yes	Is the sand free from moisture, stones, or debris, and regularly stirred or replaced?: Yes	If water is used, is it clean and sufficient in quantity?: Yes
Is the bucket placed in a designated and easily accessible location?: Yes	Are fire buckets clearly marked with reflective tape or under adequate lighting?: Yes	Is the bucket securely hung on a stand or bracket?: Yes	Is the stand painted and free from rust or corrosion?: Yes
Are workers trained on the proper use of fire buckets?: Yes	Is an inspection log maintained with dates, findings, and corrective actions?: Yes		

Signatures

Inspected by: Nakka Phanindra Kumar EHS at 04-Feb-2026 12:16 PM.	Checked by: Uma Mahesh Akki at 2/4/2026 6:48:01 AM.	Verified by: Srikanth Anumula MHC at 2/4/2026 9:38:57 AM.	Approved by: Bhimasen Beheruk at 2/11/2026 10:06:45 AM.
---	--	--	--

Inspection History

Created On	Created By	Comment	Attachments
11-Feb-2026 03:36:45 PM	Angel Woolfolk	Bhimasen Beheruk has Approved.	
11-Feb-2026 03:36:45 PM	Angel Woolfolk	Status has been updated to 'Approve'	
04-Feb-2026 03:08:57 PM	Racheal Piatt	Status has been updated to 'Verify'	
04-Feb-2026 03:08:57 PM	Racheal Piatt	Inspection has been assigned to Bhimasen Beheruk at the Approved by stage.	
04-Feb-2026 03:08:56 PM	Racheal Piatt	Srikanth Anumula MHC has Verified.	
04-Feb-2026 12:18:01 PM	Owens Strauss	Uma Mahesh Akki has Checked.	
04-Feb-2026 12:18:01 PM	Owens Strauss	Status has been updated to 'Check'	
04-Feb-2026 12:18:01 PM	Owens Strauss	Inspection has been assigned to Srikanth Anumula MHC at the Verified by stage.	

04-Feb-2026 12:16:32 PM	Caroline Su	A new record was created: Site set to 'Grava Residences' Asset Type set to 'Safety equipment' Inspection Type set to 'Fire Bucket Inspection Checklist' Status set to 'Inspection requested'	
04-Feb-2026 12:16:32 PM	Caroline Su	Inspection has been assigned to Uma Mahesh Akki at the Checked by stage.	